

Cherokee County
Development Services
1130 Bluffs Parkway
Canton, Georgia 30114

Phone Number (678) 493-6077

To Steve Roe

Developer: Johnson Development

Type of Project

☐ Commercial

☒ Residential

Permit Number: 20250000330

LDP

Phase

Grading ☒

Final

THE FOLLOWING AS NOTED:

	GOOD	NEEDS WORK	NOT IN PLACE
1. Construction Exit	☒		
2. Sediment Barriers (Silt Fence, Hay Bales, etc.)		☒	
3. Temporary Sediment Traps (Check Dams, etc.)		☒	
4. Temporary Sediment Basins		☒	
5. Storm Drain Outlet Protection	☒		
6. Soil Cover (Mulch, Temp or Perm. Vegetation)		☒	
7. Encroachment on Stream Buffer (25' State/ 50' County)		☒	
8. Sediment Contained on Site (Y/N)			
9. Pavement Clear of Sediment (Y/N)			
10. Condition of Storm water Control Devices		☒	

PHOTOGRAPHS ATTACHED ☒ CityView

Additional Site Notes: - Perimeter silt fence, sd3s and sd4s throughout site need muck out if 1/3 full or more

- Clean up new off-site sediment deposition in stream buffer

- Repair, retrench and muck out perimeter silt fence at base of slope near sd3-7

- Shore in and stabilize shear cut near sd3-7

Development Inspector Jahob Allen

Phone Number (678) 410-0064

Copies to: CityView

Field Report