

	Atlanta Airport Weekly Report			
			Day Reported	Wednesday
			Date	3/18/2026
Management of Site				
Name	Position		Phone	Email
Jerald Mitchell	VGS2M General Manager		771-210-1255	gerald.mitchell@versar.com
Cruz Santiago	VGS2M Compliance Manager		470-336-9922	Cruz.Santiago@versar.com
Sammy Exantus	VGS2M Facility Manager		771-210-1452	sammy.exantus@versar.com
Justin Deadwyler	VGS2M Program Manager		470-702-2109	justin@2mnext.com
Hours Onsite				
VGS2M Resources		Contractor		
Name	Weekly Hrs. On site	Company Name	Resource Name	Weekly Hrs. On site
Sammy Exantus	24	Environmental Restoration	OSRO	24
Jerald Mitchell	8	BASHA Services, LLC	OSRO	
Justin Deadwyler	8			
Cruz Santiago	16			
Total Hrs.	56		Total Hrs.	24
Weekly Summary				
Sites are to be inspected once a day (including weekends) for boom maintenance. Any sheen or trash along the booms are disposed of and booms are re-affixed if they become dislodged. Flint River Road - pH 6.78, temp 19.2C, BTEX concentrations below regulated limits. PAH & DRO undetected. Headwaters - pH 7.72, temp 21.2C, BTEX, PAH, DROs undetected.				
Recovery Figures				
Fuel Recovered		PCW Recovered		Note
VGS2M	16462	VGS2M	63556	VGS2M figures are from manual gauging. Last several loads of PCW were taken directly to SP Petroleum and not manually dispensed into Frac Tanks prior to disposal.
SP Total	11812	SP Total	88373	



Atlanta Airport Weekly Report Quarry (Site 1)

Day Reported	Wednesday
Date	3/18/2026

Activity Log

Planned Weekly Activities Description

Water Quality Criteria and Remedial Goals

General Comments

B - Water Samples non-scheduled or to be taken	Taken Wed 3/18
C - Water Samples status with lab (sent/scheduled return, etc.)	Results from 3/11 have been returned
D - Water Surface Inspection	No Sheen
E - PH Levels (Target 6.0 - 8.5 Std Units)	6.0 - 8.5 Std Units
F - Dissolved Oxygen (Target > 5mg/l) (enter value)	*** Sampling error
G - Temperature (Target <90F) (enter value)	18C
H - BTEX Concentrations	Not detected
H - Regulated PAH Concentrations	Not detected
J - TPH - DRO	Not detected

**Start of Week
Photos**

**End of Week
Photos**



Additional Photos

Comments

This site has not shown any evidence of sheen for the past few weeks.

BOOM Checks

Comments

Thursday 5th	Pass
Friday 6th	Fail - Re-affixed
Saturday 7th	Pass
Sunday 8th	Pass
Monday 9th	Fail - Re-affixed
Tuesday 10th	Pass
Wednesday 11th	Pass



Atlanta Airport Daily Report AATC/Employee Parking Lot #2 (Site 2)

Day Reported Wednesday
Date 3/18/2026

Activity Log

Planned Weekly Activities Description

Water Quality Criteria and Remedial Goals	General Comments
A - Water Samples non-scheduled or to be taken	Taken Wed 3/18
B - Water Samples status with lab (sent/scheduled return, etc.)	Results from 3/11 have been returned
C - Water Surface Inspection	No Sheen
D - PH Levels (Target 6.0 - 8.5 Std Units)	6.0 - 8.5 Std Units
E - Dissolved Oxygen (Target > 5mg/l) (enter value)	*** Sampling error
F - Temperature (Target <90F) (enter value)	19.9C
G - BTEX Concentrations	Detected - Below Regulated Limit
H - Regulated PAH Concentrations	Not detected
J - TPH - DRO	estimated value ≤.09mg/l

**Start of Week
Photos**



**End of Week
Photos**



Additional Photos

Comments

--	--

BOOM Checks

Comments

Thursday 5th	Pass
Friday 6th	Fail - Re-affixed
Saturday 7th	Pass
Sunday 8th	Pass
Monday 9th	Fail - Re-affixed
Tuesday 10th	Pass
Wednesday 11th	Pass



Atlanta Airport Daily Report Forest Parkway (Site 3)

Day Reported Wednesday
Date 3/18/2026

Activity Log

Planned Weekly Activities Description

Water Quality Criteria and Remedial Goals

General Comments

A - Water Samples non-scheduled or to be taken	Taken Wed 3/18
B - Water Samples status with lab (sent/scheduled return, etc.)	Results from 3/11 have been returned
C - Water Surface Inspection	No Sheen
D - PH Levels (Target 6.0 - 8.5 Std Units)	6.0 - 8.5 Std Units
E - Dissolved Oxygen (Target > 5mg/l) (enter value)	*** Sampling error
F - Temperature (Target <90F) (enter value)	22.4C
G - BTEX Concentrations	Detected - Below Regulated Limit
H - Regulated PAH Concentrations	Not detected
J - TPH - DRO	Not detected

Start of Week Photos



End of Week Photos



Additional Photos

Comments

BOOM Checks

Comments

Thursday 5th	Pass
Friday 6th	Fail - Re-affixed
Saturday 7th	Pass
Sunday 8th	Pass
Monday 9th	Fail - Re-affixed
Tuesday 10th	Pass
Wednesday 11th	Pass



Atlanta Airport Weekly Report Lee's Bridge (Site 4)

Day Reported Wednesday
Date 3/18/2026

Activity Log

Planned Weekly Activities Description

Water Quality Criteria and Remedial Goals	General Comments
A - Water Samples non-scheduled or to be taken	Taken Wed 3/18
B - Water Samples status with lab (sent/scheduled return, etc.)	Results from 3/11 have been returned
C - Water Surface Inspection	No Sheen
D - PH Levels (Target 6.0 - 8.5 Std Units)	6.0 - 8.5 Std Units
E - Dissolved Oxygen (Target > 5mg/l) (enter value)	*** Sampling error
F - Temperature (Target <90F) (enter value)	21.7C
G - BTEX Concentrations	Detected - Below Regulated Limit
H - Regulated PAH Concentrations	Not detected
J - TPH - DRO	Not detected

Start of Week
Photos



End of Week
Photos



Additional Photos

Comments

--	--

BOOM Checks

Comments

Thursday 5th	Pass
Friday 6th	Fail - Re-affixed
Saturday 7th	Pass
Sunday 8th	Pass
Monday 9th	Fail - Re-affixed
Tuesday 10th	Pass
Wednesday 11th	Pass



Atlanta Airport Weekly Report Upper Riverdale Road (Site 5)

Day Reported Wednesday
Date 3/18/2026

Activity Log

Planned Weekly Activities Description

Water Quality Criteria and Remedial Goals

General Comments

A - Water Samples non-scheduled or to be taken	Taken Wed 3/18
B - Water Samples status with lab (sent/scheduled return, etc.)	Results from 3/11 have been returned
C - Water Surface Inspection	No Sheen
D - PH Levels (Target 6.0 - 8.5 Std Units)	6.0 - 8.5 Std Units
E - Dissolved Oxygen (Target > 5mg/l) (enter value)	*** Sampling error
F - Temperature (Target <90F) (enter value)	21.8C
G - BTEX Concentrations	Detected - Below Regulated Limit
H - Regulated PAH Concentrations	Not detected
J - TPH - DRO	estimated value ≤.09mg/l

Start of Week Photos



End of Week Photos



Additional Photos

Comments

This site has the trash and debris scattered across the river.

BOOM Checks

Comments

Thursday 5th	Pass
Friday 6th	Fail - Re-affixed
Saturday 7th	Pass
Sunday 8th	Pass
Monday 9th	Fail - Re-affixed
Tuesday 10th	Pass
Wednesday 11th	Pass



Atlanta Airport Weekly Report Valley Hill Road (Site 6)

Day Reported Wednesday
Date 3/18/2026

Activity Log

Planned Weekly Activities Description

Water Quality Criteria and Remedial Goals

General Comments

A - Water Samples non-scheduled or to be taken	Taken Wed 3/18
B - Water Samples status with lab (sent/scheduled return, etc.)	Results from 3/11 have been returned
C - Water Surface Inspection	No Sheen
D - PH Levels (Target 6.0 - 8.5 Std Units)	6.0 - 8.5 Std Units
E - Dissolved Oxygen (Target > 5mg/l) (enter value)	*** Sampling error
F - Temperature (Target <90F) (enter value)	20.4C
G - BTEX Concentrations	Not detected
H - Regulated PAH Concentrations	Not detected
J - TPH - DRO	Not detected

Start of Week Photos



End of Week Photos



Additional Photos

Comments

No visible sheen. Site has trash that accumulates across booms.

BOOM Checks

Comments

Thursday 5th	Pass
Friday 6th	Fail - Re-affixed
Saturday 7th	Pass
Sunday 8th	Pass
Monday 9th	Fail - Re-affixed
Tuesday 10th	Pass
Wednesday 11th	Pass