



April 26, 2021
VIA ELECTRONIC MAIL

Mr. Jason R. Pietras
State On-Scene Coordinator
Georgia Environmental Protection Division
Mountain District – Cartersville Office
16 Center Road
Cartersville, Georgia 30120

Subject: Georgia Power –Spill Event Follow-Up Documentation

Dear Mr. Pietras:

As discussed on April 19, 2021, in lieu of sending separate Release and Remediation Reports for the following spill events, Georgia Power is submitting this letter to serve as the follow-up report and closure notification:

1. CTS 90250: 23 June 2019, 6199 Riverside Drive in Sandy Springs, Fulton Co. Pole # 30038.
2. CTS 91661: 9 November 2019, 510 Thicket Way in Decatur, Dekalb Co. Transformer # 510773.
3. CTS 91696: 13 November 2019, 4899 Pinnacle Drive in Stone Mountain, Dekalb Co.
4. CTS 91708: 15 November 2019, 981 Old Augusta Road in Rincon, Effingham Co.
5. CTS 91984: 23 December 2019, 3594 Kingsboro Road NE Atlanta, Fulton Co.
6. CTS 92060: 3 January 2020, 435 Pine Vista Drive in Macon, Bibb Co.
7. CTS 92085: 6 January 2020, 2710 Jefferson Street in Austell, Cobb Co.

Items 1 – 3 and 5 – 7 were oil spills that entered state waters. For these six (6) events, the spill cleanup generally included the following actions:

- Retrieval of oil (that spilled from the transformer) from the ground, pavement, catch basins, storm water drainage systems, including detention ponds, and, where possible, any standing/flowing waters.
- Excavation of impacted soils and removal of used oil absorbent material
- Backfilling and tamping with clean soil and placing grass seed and mulch, or grass sod, in the affected area
- Placement and subsequent removal of absorbents booms, pads, etc. from storm drain inlets and outlets following subsequent rain events.
- Disposal of oil-containing soil and debris at permitted landfills (typically Waste Management's Turkey Run Landfill in Hogansville, GA)

GPC Spill Event Follow-Up Documentation to Georgia EPD

April 26, 2021

Page 2

All waste from these spills was non-PCB and sent to a RCRA Subtitle D landfill for disposal. Waste manifests and/or bills of lading for Items 1 and 6 are enclosed with this letter; those for the other spill events can be provided at a later date, if needed.

For Item 4, the spill was a chemical spill that was discharged from Georgia Power's Plant McIntosh power generating facility in Rincon, GA. The spill occurred during a significant rain event and was initially reported to the EPD Emergency Operations Center along with the National Response Center. However, upon further investigation, the discharge occurred from an NPDES Industrial Stormwater permitted outfall. Follow-up reporting was made to David Lyle in the Coastal District office; see attached report from November 20, 2019.

If you have any questions or need additional information, please do not hesitate to contact me by phone at (770) 367-5183 or via e-mail at jbwether@southernco.com.

Sincerely,

A handwritten signature in black ink, appearing to read "Burns Wetherington". The signature is stylized and cursive, written over a horizontal line.

Burns Wetherington, P.E.
Environmental Affairs Principal Engineer

Encl: CTS 90250 Waste Manifest
CTS 92060 Waste Manifest
CTS 91708 NPDES Unpermitted Discharge Notification Letter