Cherokee County
1831
GEORGIA

ENGINEERING DEPARTMENT
1130 Bluffs Parkway – Canton, Georgia 30114
678-493-6077 – Fax 678-493-6055

SITE DEVELOPMENT INSPECTION FORM

Project Name: LAH - Phase 2 Unit 12 **PL:** 20250000330

Date: 8/13/25 **Arrived:** 10:45 am **Departed:** 12:15 am **Inspector:** Jakob Allen

Inspection Type:

- ☒ General Site Inspection
- ☒ Erosion Control Inspection
- ☐ Stormwater Inspection
- ☐ Transportation Inspection
- ☐ Complaint Inspection
- ☐ Punch List Inspection

Inspection Description:

Routine inspection

Inspection Conditions/Notes:

- Cloudy weather conditions
- Activity on site
- Clearing throughout site continues
- CO pad being refreshed
- Road being cleaned
- Work on retaining wall has progressed
- Several sections of perimeter silt fence throughout site needs mucking out
- Concrete waste in 12A needs cleaning up
- Install concrete washout

Outcome:

- ☐ Permit Issued
- ☐ Non-Compliance
- ☐ Stop Work Order
- ☐ Inspection Passed
- ☒ Inspection Failed
- ☐ Other

Followup Inspection Needed: ☐ No ☒ Yes If Yes, Date Needed: Within 7 days

Developer Contacted:

Contact Name: Mike Harper (336) 467-5566 / Luis Saturnino (404) 416-0266

- ☒ Via Phone
- ☐ Via E-Mail
- ☐ In Person