Cherokee County
1831
GEORGIA

ENGINEERING DEPARTMENT
1130 Bluffs Parkway – Canton, Georgia 30114
678-493-6077 – Fax 678-493-6055

SITE DEVELOPMENT INSPECTION FORM

Project Name: LAH - Phase 2 Unit 12 **PL:** 20250000330

Date: 5/19/25 **Arrived:** 9:30 am **Departed:** 12:00 am **Inspector:** Jakob Allen

Inspection Type:

- ☒ General Site Inspection
- ☒ Erosion Control Inspection
- ☐ Stormwater Inspection
- ☐ Transportation Inspection
- ☐ Complaint Inspection
- ☐ Punch List Inspection

Inspection Description:

Routine inspection

Inspection Conditions/Notes:

- Cloudy weather conditions
- Activity on site
- Grading at front of site continues
- Fuel tank not entrenched or lined
- No CO pad for entrance on S Cherokee Dr
- Several areas of off-site sediment deposition need to be brought within LOD
- Damaged perimeter silt fence needs repairing
- Several areas of exposed dirt need stabilization with grass seed, wheat straw and slope matting

Outcome:

- ☐ Permit Issued
- ☒ Non-Compliance
- ☒ Stop Work Order
- ☐ Inspection Passed
- ☒ Inspection Failed
- ☐ Other

Followup Inspection Needed: ☐ No ☒ Yes If Yes, Date Needed: Within 7 days

Developer Contacted:

Contact Name: Mike Harper (336) 467-5566

- ☒ Via Phone
- ☐ Via E-Mail
- ☐ In Person