

Cherokee County
Development Services
1130 Bluffs Parkway
Canton, Georgia 30114

Phone Number (678) 493-6077

To Steve Roe
Developer: Johnson Development

Type of Project

☐ Commercial

☒ Residential

Permit Number: PL 20250000330

LDP

Phase

Grading ☒

Final ☐

THE FOLLOWING AS NOTED:

	GOOD	NEEDS WORK	NOT IN PLACE
1. Construction Exit		☒	
2. Sediment Barriers (Silt Fence, Hay Bales, etc.)		☒	
3. Temporary Sediment Traps (Check Dams, etc.)		☒	
4. Temporary Sediment Basins		☒	
5. Storm Drain Outlet Protection			
6. Soil Cover (Mulch, Temp or Perm. Vegetation)		☒	
7. Encroachment on Stream Buffer (25' State/ 50' County)	☒		
8. Sediment Contained on Site (Y/N)			
9. Pavement Clear of Sediment (Y/N)			
10. Condition of Storm water Control Devices		☒	

PHOTOGRAPHS ATTACHED (Y/N) ☒ CityView

Additional Site Notes: - Expend and refresh CO pad
- Remove all equipment from diversion at front of site
- Re-apply slope matting at front of site diversion
- Muck out sd3-7 and sd3-16 and free up skimmers
- Ensure all slopes are 2:1 and marked
- Have most recent revision to plans on site
- Ensure no more than 17 acres are disturbed at any one time

Development Inspector Jahob Allen

Phone Number (678) 410-0664

Copies to: Steve Roe, Mike Harper,

CityView

Field Report

Project	<u>LAH Phase 2 Unit 12</u>
Non-Compliance issued (Y/N)	<u>(Y/N)</u>
Stop Work Order issued (Y/N)	<u>(Y/N)</u>
Citation issued (Y/N)	<u>(Y/N)</u>
Date & Time	<u>8/20/25 10:30 am</u>
Location	<u>Lake Arrowhead Dr</u>
Contractor	<u>Pogwood Sites</u>
Developer Purpose of visit	<u>EPD joint inspection</u>
Present at site	<u>Myself</u>